

CATTARAUGUS COUNTY

DEPARTMENT OF PUBLIC WORKS

ADDENDUM NO. 1

FOR

BID No. 43

Cattaraugus County Jail - 2022 Parking Lot Expansion

Cattaraugus County Center
301 Court Street
Little Valley, NY

ADDENDUM DATE: 15 JULY 2022

The following are clarifications to the bid specifications and plans:

1. Sheet 2 of 3: Note 5 – It is the assumption of the County that the 3 existing drywells shown on the plans are stone filled drywell and no large voids are anticipated. If in the event the drywells are not filled, then the work to fill these drywells will be considered out-of-scope and a change order will be negotiated to address that situation.

Changes to the plans and bid proposal booklet:

Plans: Sheet 2 of 3: Note 4: The following shall be added to the end of Note 4:

“The top course pavement shall meet the material specifications for either 9.5 F3 Top Course HMA or WMA (Items 402.098304 or 404.098301 respectively). The Binder Course shall meet the material specifications for either 19 F9 Binder Course HMA or WMA (Items 402.198904 or 404.198901 respectively).”

ALL BIDDERS MUST RETURN THIS ADDENDUM WITH THE BID AND RECORD THIS ADDENDUM IN SECTION B ON SHEET B-2 IN THE BID PROPOSAL BOOK.

IN ADDITION, PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM 1 IMMEDIATELY BY PROVIDING THE INFORMATION BELOW AND FAXING THIS SHEET TO:

Cattaraugus County
Department of Public Works
(716) 938-2754

Company Name: _____ Signed: _____

Date: _____ Printed Name of Signatory: _____